

**ADDENDUM NO. 3**  
**PALMETTO ROAD AT ARROWOOD/SPENCER LANE ROUNDABOUT**  
**PW-2021-13-04**  
**TYRONE, GEORGIA**  
**January 11, 2024**

The following changes, modifications, and/or clarifications to the project documents are a part, thereof, and change the original documents only in a manner and to the extent stated.

1. Bidders are reminded to comply with all the requirements for bidding as enumerated in the Project Manual, INCLUDING ACKNOWLEDGEMENT OF THE RECEIPT OF THIS ADDENDUM ON THE BID FORM.
2. Reference is made to the bid form of Addendum 2, page 13: Item 112 - Jack and Bore Pipe, Steel Casing. The diameter for the steel casing shall be 12" with a minimum wall thickness of 0.250 inches.

**End of Addendum No. 3**